

県庁地下駐車場における湧水槽の排水状況について

R8.8.31時点

回数	排水日	排水量	水質検査結果 *1			備 考
			PFOS	PFOA	合計値 *2	
1	R8.3.30	4,700L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
2	R8.4.14	3,000L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
3	R8.4.28	2,000L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
4	R8.5.11	5,900L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
5	R8.5.15	4,400L	0.3ng/L	<0.2ng/L	0.5ng/L	
6	R8.5.22	3,400L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
7	R8.5.29	4,000L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
8	R8.6.6	3,200L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
9	R8.6.11	6,000L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
10	R8.6.15	6,200L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
11	R8.6.18~6.24	28,500L	<0.2ng/L	<0.2ng/L	<0.4ng/L	自動排水へ切替
12	R8.6.25~7.1	10,200L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
13	R8.7.2~7.15	3,800L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
14	R8.7.16~7.31	5,100L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
15	R8.8.1~8.14	5,000L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
16	R8.8.15~8.31	15,300L	<0.2ng/L	<0.2ng/L	<0.4ng/L	
17						
18						
19						
20						
	累計	110,700L				

*1 定量下限値（分析値として定量し得る最小の濃度）：0.2ng/L

*2 採水箇所：県庁地下駐車場に設置した二次浄化水槽内

「公共用水域・地下水における指針値」及び「水道水における基準値」：50ng/L以下（PFOSとPFOAの合計値）